



Hazardous Materials Discharge Summary Report

This is the most recent weekly report of hazardous materials discharges in Ventura County, California. If you need copies of previous week's reports, or would like additional information, please call (805)654-2813.

<i>Date of Incident</i>	<i>Location</i>	<i>Material</i>	<i>Estimated Amount</i>
8/5/2023 Rpt#: 102683	1039 VENTURA ST FILLMORE	SEWAGE	250 GALLON(S)
Description: Bypass pump failure caused manhole to overflow.			
8/8/2023 Rpt#: 102684	540 SPECTRUM CIRCLE OXNARD	PROCESS SOLUTION	1 GALLON(S)
Description: Operator overfilled storage tank, causing release.			
8/9/2023 Rpt#: 102685	3600 HARBOR BLVD OXNARD	OIL	UNKNOWN UNKNOWN
Description: Oil sheen from unknown source.			
8/10/2023 Rpt#: 102686	HWY 126 AND C STREET FILLMORE	SEWAGE	200 GALLON(S)
Description: Bypass pump failed causing release from manhole.			

The locations of these releases are given by post office address whenever possible. These addresses include city name, however, no determination as to the location of the release relative to the corporate boundaries of any city is intended.