

**COUNTY OF VENTURA  
PUBLIC WORKS AGENCY**

Date: April 18, 2024

To: All Prospective Bidders

From: Dave Fleisch  
Interim County Engineer **Addendum No. 3**

Subject: **Project Name: El Rio Pedestrian Improvements**  
**Specification No. RD24-05 Project No. 50616**  
**State Project No. ATPSB1L-5952(208)**  
**Bids to be Opened: April 23, 2024 (NO CHANGE IN BID DATE)**

Make the following modifications to the bidding documents for subject project:

1. Construction Note #41 on all plan sheets is hereby revised to read as follows:  
"WATER COMPANY TO ADJUST FIRE HYDRANT AND/OR WATER VALVE TO MATCH NEW FINISH SURFACE. CONTRACTOR SHALL COOPERATE WITH WATER COMPANY"
2. Construction Note #43 on all plan sheets is hereby revised to read as follows:  
"WATER COMPANY TO RELOCATE FIRE HYDRANT AND/OR WATER VALVE AND WILL ADJUST TO MATCH NEW FINISH SURFACE. CONTRACTOR SHALL COOPERATE WITH WATER COMPANY"
3. Specification Section 1048-3, MATERIAL, is hereby revised to read as follows:  
"Asphalt concrete used in AC pavement widening shall be C2-PG64-10."
4. Clarification: This contract allows the use of recycled asphalt pavement (RAP) in the AC mix. If 25% or more of RAP is included in the mix, contractor shall modify the asphalt binder as required in SSPWC Section 203-6.3.2, such that PG64-10 shall become PG58-22.

Bidders are required to acknowledge any Addenda in Bonfire before submitting their bid.

Approved:   
\_\_\_\_\_  
Dave Fleisch, Interim County Engineer

4/18/2024  
\_\_\_\_\_  
Date Approved