

Hazardous Materials Discharge Summary Report

This Summary Report is a list of all reports of incidents received from
02/08/25 through 02/14/25

<i>Date of Incident</i>	<i>Location</i>	<i>Material</i>	<i>Estimated Amount</i>
2/12/2025	1372 CALLE AVELLANO	CALCIUM CHLORATE	0.00661387 POUND(S)
<i>Rpt#:</i> 102896	THOUSAND OAKS	RED PHOSPHOROUS	0.00661387 POUND(S)
<i>Description:</i> A teenager mixed the two materials for a potential rocket propulsion. The mixture resulted in a small explosion inside the resident's garage.			
2/13/2025	251 HARBOR BLVD	CARBON DIOXIDE	1000 POUND(S)
<i>Rpt#:</i> 102898	OXNARD		
<i>Description:</i> A building fire detection system malfunction causing the fire suppression to discharge 1000 lbs. of CO2 gas into the atmosphere.			

The locations of these releases are given by post office address whenever possible. These addresses include city name, however, no determination as to the location of the release relative to the corporate boundaries of any city is intended.