

# ***Hazardous Materials Discharge Summary Report***

This Summary Report is a list of all reports of incidents received from  
10/16/2021 through 10/22/2021

<b><i>Date of Incident</i></b>	<b><i>Location</i></b>	<b><i>Material</i></b>	<b><i>Estimated Amount</i></b>
10/20/2021 <i>Rpt#:</i> 102309	2950 PIERPONT BLVD VENTURA	RAW SEWAGE	30 GALLON(S)
<i>Description:</i> MAINTENANCE WORK WAS BEING CONDUCTED ON A LIFT STATION WHEN SEWAGE OVERFLOWED ONTO THE GROUND AT MARINA PARK.			

---

The locations of these releases are given by post office address whenever possible. These addresses include city name, however, no determination as to the location of the release relative to the corporate boundaries of any city is intended.

---